

OFFICE USE ONLY
 Log No. 50415
 Permit No. 009
 Basin. NIA

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28065

1. OWNER John Beeze ADDRESS AT WELL LOCATION 7960 Weatherby Rd
 MAILING ADDRESS P.O. Box 807
WINNEMUCCA, NV 89446
 2. LOCATION SE 1/4 SE 1/4 Sec 31 T. 40 S R. 39 E Humboldt County
 PERMIT NO. 06-049-01 Parcel No. NIA Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	20	20
SAND/clay		20	30	10
SAND/gravel		30	50	20
SAND/gravel/clay		50	70	20
gravel-85% SAND - 15%		70	90	20
gravel/silty SAND		90	120	30
gravel/SAND		120	150	30

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 7/8 Inches To 0 Feet 150 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 7/8</u>	<u>12</u>	<u>1.88</u>	<u>0</u>	<u>150</u>

Perforations:
 Type perforation Factory Cuts
 Size perforation 3/32
 From 130 feet to 150 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 150 feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow NO G.P.M. NIA P.S.I.
 Water temperature cool °F Quality Good

Date started 8/24, 1995
 Date completed 8/25, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>45</u>	<u>NIA</u>	<u>3 hr.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FRED ANDERSON Contractor
 Address 10760 Grass Vly Rd Contractor
WINNEMUCCA, NV
 Nevada contractor's license number issued by the State Contractor's Board 0021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8-31-95