WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50421
Permit No.
Basin 104

NOTICE OF INTENT NO. 28016

1. OWNER Stan Smith
MAILING ADDRESS 3030 King Canyon Rd Carson City NV. 89701
ADDRESS AT WELL LOCATION 3230 Kings Canyon Rd Carson City NV. 89701

2. LOCATION SW ¼ SW ¼ Sec. 13 T. 15 N/S R. 19 E. Carson County
PERMIT NO. Issued by Water Resources
7-081-17 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gummy Clay		0	10	10
Large Cobbles		10	38	28
DG Sands w/Clay Seams		38	63	25
Hard Black obsidian Gravels		63	94	31
Black & White Granite		94	130	36
Broken DG Coarse and Hard		130	147	17
Hard Obsidian Granite		147	180	33
Broken Coarse Sands xxx Hard and Very Broken Rusty Sands		180	220	40

Date started 6/25, 1995
Date completed 6/29, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	65	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10¼	Inches	0	Feet	50	Feet
9⅞	Inches	50	Feet	220	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	220

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 180 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Company (Contractor)
Address 5551 Hwy 50 E #3 Carson City NV. 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6/30/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627