

OFFICE USE ONLY
 Log No. 50447
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

19BDBP

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31885

1. OWNER Gary Maas ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3100 Calle Verde Ct. 4691 Bacon Rind Rd. Sparks
Sacramento, CA Reno, NV
 2. LOCATION SSWE 1/4 NW 1/4 Sec 19 T. 22N N/S R. 21 E Washoe County
 PERMIT NO. 076-220-14 Parcel No. Palomino J. Unit # 7 19.2.1.1 par. 5 Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Red yellow orange vol sands		0	1	
Red vol rock hard		1	49	
Light green & red clay w/green yellow red vol sands		49	135	
Orange vol rock		135	186	
Light green yellow red vol rock		186	248	
Green clay with vol sand zones		248	385	
Green & tan clay stone w/vol sand		385	415	
Coarse vol sands w/small green clay zones		415	470	
T.D. 470				

8. WELL CONSTRUCTION
 Depth Drilled 470 Feet Depth Cased 470 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10-5/8 Inches 0 Feet 56 Feet
8-1/2 Inches 56 Feet 470 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	1292	.188	+1-1/2	470

Perforations:
 Type perforation factory-sawed
 Size perforation 3/32 x 3"
 From 450 feet to 430 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 54 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 470 feet to 54 feet

9. WATER LEVEL
 Static water level 280 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 9/22, 1995
 Date completed 9/25, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>15</u>		<u>3</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. PUMP & WELL SERVICE, INC Contractor
 Address 1800-1/2 Frazer Avenue Contractor
Sparks, Nevada 89431
 Nevada contractor's license number 35387A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller
 Signed Gary Welch
 By driller performing actual drilling on site or contractor
 Date October 1, 1995