

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16762

1. OWNER Janet H. Harvey ADDRESS AT WELL LOCATION 710 W. Janet Lane
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 SW 1/4 Sec 33 T 19-S N/S R 53 E Nye County _____
 PERMIT NO. 29-831-23 Parcel No. _____ Rancho Del Sol Unit: 1 Blk: 1
Issued by Water Resources Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____


6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|----------------------|--------------|------|-----|-----------|
| Surface | | 0 | 4 | 4 |
| Brown clay | | 4 | 52 | 48 |
| Brown clay & caliche | | 52 | 68 | 16 |
| Brown clay | X | 68 | 92 | 24 |
| Brown clay & caliche | | 92 | 107 | 15 |
| Brown clay | X | 107 | 128 | 21 |
| Brown clay & caliche | | 128 | 140 | 12 |

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 8 5/8 | 16.94 | .188 | 0 | 140 |

Perforations:
 Type perforation Torch Cut
 Size perforation 1/4" width 8" long
 From 100 feet to 140 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type _____
 Depth of Seal 50 _____
 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 140 feet



9. WATER LEVEL
 Static water level 51 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started December 19, 1995
 Date completed December 19, 1995

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | 20 | 4 | 1/4 |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Jim Pike Well Drilling, LLC Contractor
 Address P.O. Box 56 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 17563A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date December 29, 1995