WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50473
Permit No.
Basin 162

NOTICE OF INTENT NO. 16994

1. OWNER Wendell Sinyard
MAILING ADDRESS
ADDRESS AT WELL LOCATION 610 Pitz

2. LOCATION NE ¼ NW ¼ Sec 9 T 20 S N/S R 53 E Nye County
PERMIT NO. (Issued by Water Resources) 35-161-26 (Parcel No.) Cal Vegas Ranches (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Calichie		4	7	3
Clay		7	16	9
Calichie		16	21	5
Clay		21	41	20
Calichie		41	43	2
Clay		43	50	7
Calichie	WB	50	53	2
Clay		53	58	6
Calichie	WB	58	61	3
Clay		61	68	7
Calichie	WB	68	70	2
Clay		70	87	17
Calichie	WB	87	91	4
Clay		91	100	9
Calichie	WB	100	103	3
Clay		103	112	9
Calichie	WB	112	114	2
Clay		114	123	9
Calichie	WB	123	125	2
Clay		125	132	7
Calichie	WB	132	134	2
Clay		134	140	6

DCNR/DWR Received JAN 5 1996 LAS VEGAS OFFICE

Date started December 11, 19 95
Date completed December 13, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 1 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box 4220 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1642
Signed (By driller performing actual drilling on site or contractor)
Date 12-29-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627