WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50976
Permit No.
Basin 162

NOTICE OF INTENT NO. 17327

1. OWNER Randy Kampen
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3921 Percheron

2. LOCATION SW ¼ SE ¼ Sec. 35 T. 20 S N/S R. 53 E Nye County
PERMIT NO. (Issued by Water Resources) 41-192-09 (Parcel No.) Calvada (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	5
Limestone		5	12	7
Clay		12	26	14
Calichie		26	28	2
Clay		28	39	11
Calichie		39	42	3
Clay		42	54	12
Calichie	WB	54	57	3
Clay		57	63	6
Calichie	WB	63	65	2
Clay		65	76	11
Calichie	WB	76	81	5
Clay		81	90	11
Calichie	WB	90	92	2
Clay		92	104	12
Calichie	WB	104	107	3
Clay		107	119	12
Calichie	WB	119	123	4
Clay		123	136	13
Calichie	WB	136	140	4

DCNR/DWR Received JAN 5 1996 LAS VEGAS OFFICE

Date started November 14, 1995
Date completed November 16, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 8" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box 4220 (Contractor)
Pahrump, NV. 89041-4220
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 12/27/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627