



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13476

1. OWNER JIM MASCARO ADDRESS AT WELL LOCATION SHOAN  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 SE 1/4 Sec. 19 T. 23 N. R. 6.1 E. CLARK County  
 PERMIT NO. 54601 | 400-230-010 Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders & Clay		0	190	190
Gray Limestone		190	580	390
Red Sandstone		580	590	10
Gray Limestone	X	590	630	40
Red Sandstone		630	640	10
Gray Limestone	X	640	720	80
	700'			

8. WELL CONSTRUCTION

Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)

From	To
1 1/4 Inches	0 Feet 720 Feet
Inches	Feet Feet
Inches	Feet Feet



CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 3/8		.188	12	720

Perforations:  
 Type perforation Torch  
 Size perforation 1/4 x 10"  
 From 640 feet to 720 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type \_\_\_\_\_  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 720 feet



Date started 12-4 1995  
 Date completed 12-29 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
900 CFM @	250 psi @ 720'	
Approx. 100 gpm AFTER 3 hrs Development		
AIR TEST		

9. WATER LEVEL  
 Static water level 540 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature WARM °F Quality OK

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name DEAN MITCHELL Contractor  
 Address 4250 S. ARVILLE Contractor  
L.V. Nev. 89103  
 Nevada contractor's license number issued by the State Contractor's Board 027030  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1617  
 Signed Dean Mitchell  
 By driller performing actual drilling on site or contractor  
 Date 12-30-95