



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15479

1. OWNER Forrest D Johnson ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NW 1/4 SE 1/4 Sec. 36 T 21 N 60 E CLARK County \_\_\_\_\_  
 PERMIT NO. 55035 Issued by Water Resources Parcel No. 163-36-701-021 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE RM  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Consolidated Claygravel</u>		<u>0</u>	<u>315</u>	<u>315</u>
<u>GRAVEL</u>	<u>X</u>	<u>315</u>	<u>325</u>	<u>10</u>
<u>Consolidated gravel</u>		<u>325</u>	<u>390</u>	<u>65</u>
<u>GRAVEL</u>	<u>X</u>	<u>390</u>	<u>417</u>	<u>27</u>

8. WELL CONSTRUCTION  
 Depth Drilled 417 Feet Depth Cased 417 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
9 7/8 Inches 0 Feet 417 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.75</u>		<u>.188</u>	<u>+1 1/2</u>	<u>417</u>

Perforations:  
 Type perforation Torch  
 Size perforation \_\_\_\_\_  
 From 320 feet to 417 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type: \_\_\_\_\_  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Neat Cement  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 417 feet

9. WATER LEVEL  
 Static water level 300 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality OK

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Dean Mitchell Contractor  
 Address 4255 ARVILLE APT 262 89103 Contractor  
L.V. Nev.

Nevada contractor's license number issued by the State Contractor's Board 27030  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1617  
 Signed Dean Mitchell  
 By driller performing actual drilling on site or contractor  
 Date 2-1-96

Date started 1-22, 1996  
 Date completed 2-1, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>70</u>	<u>450 CFM @ 250 PSI</u> <u>417' 1 hr</u>	

