

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16292

1. OWNER Wilden's Pride Dodge ADDRESS AT WELL LOCATION 4701 W. Sahara Ave  
 MAILING ADDRESS 4701 W. Sahara Ave, Las Vegas NV. 89102  
Las Vegas NV. 89102

2. LOCATION NE 1/4 NW 1/4 Sec. 07 T 21 N8 R 61 E Clark County

PERMIT NO. MO-2646 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Artesian

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>silty sand + Gravel</u>		<u>0'</u>	<u>3.5'</u>	<u>3.5'</u>
<u>silty sand</u>		<u>3.5</u>	<u>8.0</u>	<u>1.5'</u>
<u>caliche</u>		<u>5.</u>	<u>6</u>	<u>1</u>
<u>silty sand/caliche</u>		<u>6</u>	<u>7.5</u>	<u>1.5</u>
<u>caliche</u>		<u>7.5</u>	<u>8.5</u>	<u>1</u>
<u>silt w/ calich nodules</u>		<u>8.5</u>	<u>10</u>	<u>1.5</u>
<u>Clay w/ silt</u>		<u>10</u>	<u>17</u>	<u>7</u>
<u>silty sand wet</u>	<u>17'</u>	<u>17'</u>	<u>27'</u>	
<u>hard caliche TD</u>		<u>27'</u>		

8. WELL CONSTRUCTION  
 Depth Drilled 27' Feet Depth Cased 27' Feet

HOLE DIAMETER (BIT SIZE)  
 From 8" Inches To 0 Feet 2.5 Feet  
 Inches Feet Feet  
 Inches Feet Feet


CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.64 lbs</u>	<u>0.218</u>	<u>0'</u>	<u>27'</u>

Perforations:  
 Type perforation Factory slot  
 Size perforation 0.20  
 From 12' feet to 27' feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 10'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 10' feet to 27' feet



Date started Oct 25, 1995  
 Date completed Oct 25, 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level feet below land surface  
 Artesian flow G.P.M. P.S.I.  
 Water temperature °F Quality

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Thomas R. High Contractor  
 Address 731 Pilot rd suite H  
Las Vegas NV. 89119  
 Nevada contractor's license number issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869  
 Signed Thomas R. High  
 By driller performing actual drilling on site or contractor  
 Date Dec 12, 1995