WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

DCNR/DWR Received NOV 15 1995 LAS VEGAS OFFICE

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50540
Permit No.
Basin

NOTICE OF INTENT NO. 12288

1. OWNER Raymon Robert
MAILING ADDRESS

ADDRESS AT WELL LOCATION 1861 Wilson Rd

2. LOCATION NW ¼ SW ¼ Sec. 17 T. 20S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 36-291-06 (Parcel No.) Cal Vegas Ranchos (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	7	7
Calichie		7	9	2
Clay		9	16	7
Calichie		16	18	2
Clay		18	32	12
Calichie		32	38	6
Clay		38	51	13
Calichie	WB	51	54	3
Clay		54	65	11
Calichie	WB	65	68	3
Clay		68	76	11
Calichie	WB	76	78	2
Clay		78	89	11
Calichie	WB	89	91	2
Clay		91	99	8
Calichie	WB	99	102	4
Clay		102	113	11
Calichie	WB	113	117	4
Clay		117	131	14
Calichie	WB	131	135	4
Clay		135	140	5

Date started October 12, 1995
Date completed October 16, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛ x 3
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 10/17/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627