

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 20558  
 Permit No. \_\_\_\_\_  
 Basin 1  
 NOTICE OF INTENT NO. 17325

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Cornett ADDRESS AT WELL LOCATION 301 Hickory  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE 1/4 SE 1/4 Sec. 28 T. 20 S N/S R. 53 E Nye County  
 PERMIT NO. 40-402-13 Calvada  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	7	7'
Caliche		7	11	4'
Clay		11	18	7'
Caliche		18	23	5'
Clay		23	38	15'
Caliche		38	42	4'
Clay		42	55	13'
Caliche	W.B.	55	58	3'
Clay		58	67	9'
Caliche	W.B.	67	70	3'
Clay		70	81	11'
Caliche	W.B.	81	83	2'
Clay		83	94	11'
Caliche	W.B.	94	96	2'
Clay		96	112	16'
Caliche	W.B.	112	115	3'
Clay		115	124	9'
Caliche	W.B.	124	129	5'
Clay		129	136	7'
Caliche	W.B.	136	138	2'
Clay		138	140	2'

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Factory Sawcut  
 Size perforation 1/8" x 3"  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Groat Basin Drilling Contractor  
 Address P.O. box 4220 Contractor  
Pahrump NV 89041-4220  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas D...  
 By driller performing actual drilling on site or contractor  
 Date 11/29/95

Date started 11-6, 1995  
 Date completed 11-9, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

