

Log No. 50559  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17326

1. OWNER Paulsen ADDRESS AT WELL LOCATION 2340 S. Zephyr  
MAILING ADDRESS \_\_\_\_\_  
2. LOCATION SW 1/4 NW 1/4 Sec. 29 T 20 S N/S R 53 E NYC County \_\_\_\_\_  
PERMIT NO. 39-013-03 calvada Subdivision Name \_\_\_\_\_  
Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3'
Caliche		3	5	2'
Clay		5	19	14'
Caliche		19	23	4'
Clay		23	31	8'
Caliche		31	34	3'
Clay		34	43	9'
Caliche		43	45	2'
Clay		45	54	9'
Caliche	W.B.	54	57	3'
Clay		57	68	11'
Caliche	W.B.	68	71	3'
Clay		71	93	22'
Caliche	W.B.	93	96	3'
Clay		96	115	19'
Caliche	W.B.	115	117	2'
Clay		117	124	7'
Caliche	W.B.	124	126	2'
Clay		126	131	5'
Caliche	W.B.	131	134	3'
Clay		134	140	6'

8. WELL CONSTRUCTION  
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)  
From 12 1/4 Inches To 0 Feet 140 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:  
Type perforation Factory Sawcut  
Size perforation 18" x 3"

From 120 feet to 120 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
From 50 feet to 140 feet

9. WATER LEVEL  
Static water level 54 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Great Basin Drilling Contractor  
Address P.O. Box 4220 Contractor  
Pahrump NV 89041-4220  
Nevada contractor's license number 30880  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1642  
Signed Thomas Dan  
By driller performing actual drilling on site or contractor  
Date 12/8/95

Date started 11-6 1995  
Date completed 11-9 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

