WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50561
Permit No.
Basin

NOTICE OF INTENT NO. 16974

1. OWNER Lester McKillips
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4700 S. Elizabeth

2. LOCATION NE ¼ SW ¼ Sec. 2 T. 21 S N/S R. 53 E Nye County
PERMIT NO. (Issued by Water Resources) 44-072-22 (Parcel No.) Manko (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	6	6'
Caliche		6	9	3'
Clay		9	18	9'
Caliche		18	20	2'
Clay		20	31	11'
Caliche		31	34	3'
Clay		34	43	9'
Caliche		43	45	2'
Clay		45	52	7'
Caliche	W.B	52	54	2'
Clay		54	67	13'
Caliche	W.B	67	69	2'
Clay		69	80	11'
Caliche	W.B.	80	83	3'
Clay		83	92	9'
Caliche	W.B	92	95	3'
Clay		95	103	8'
Caliche	W.B.	103	107	4'
Clay		107	114	7'
Caliche	W.B.	114	116	2'
Clay		116	125	9'
Caliche	W.B.	125	129	4'
Clay		129	136	7'
Caliche	W.B.	136	138	2'
Clay		138	140	2'

DCNR/DWR Received DEC 12 1995 LAS VEGAS OFFICE

Date started Nov. 24, 1995
Date completed Nov. 26, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw cut
Size perforation ⅛ x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box 4220 (Contractor)
Pahrump, NV 89041-4220
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dow (By driller performing actual drilling on site or contractor)
Date 12/8/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627