WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50564
Permit No.
Basin

NOTICE OF INTENT NO. 14358

1. OWNER Carolynn Williams
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1761 Carson

2. LOCATION SE ¼ NE ¼ Sec. 14 T. 21S N/S R. 53 E. NVE County
PERMIT NO. (Issued by Water Resources) 44-633-09 (Parcel No.) Stardust (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4'
Caliche		4	6	2'
Clay		6	17	11'
caliche		17	19	2'
Clay		19	32	13'
Caliche		32	35	3'
Clay		35	44	9'
Caliche		44	47	3'
Clay		47	52	5'
Caliche	W. B.	52	55	3'
Clay		55	66	11'
Caliche	W. B.	66	68	2'
Clay		68	88	20'
Caliche	W. B.	88	91	3'
Clay		91	100	9'
Caliche	W. B.	100	109	9'
Clay		109	119	10'
Caliche	W. B.	119	123	4'
Clay		123	136	13'
Caliche	W. B.	136	139	3'
Clay		139	140	1'

DCNR/DWR Received DEC 12 1995 LAS VEGAS OFFICE

Date started 11-14, 1995
Date completed 11-17, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Sawcut
Size perforation 1/8" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address Po Box 4220 (Contractor)
Pahrump NV 89041-4220
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 12/6/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627