

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **17458**

1. OWNER Penni Stratton ADDRESS AT WELL LOCATION 3050 Our Road  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE 1/4 SE 1/4 Sec. 1 T 20S N/S R 52 E Nye County  
 PERMIT NO. 28-432-20 Vegas Acres Subdivision Name \_\_\_\_\_  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	60	60
Caliche	WB	60	62	2
Clay		62	70	8
Caliche	WB	70	73	3
Clay		73	95	22
Caliche	WB	95	98	3
Clay		98	115	17
Caliche	WB	115	118	3
Clay		118	128	10
Caliche	WB	128	131	3
Clay		131	137	6
Caliche	WB	137	140	3

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 2 1/4 Inches 0 Feet 140 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations: Factory Saw Cut  
 Type perforation \_\_\_\_\_  
 Size perforation 1 1/8" x 3"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 46 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started December 26 1995  
 Date completed December 28 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address P.O. Box 4220 Contractor  
Pahrump, NV. 89041  
 Nevada contractor's license number 30880  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1642  
 Division of Water Resources, the on-site driller:  
 Signed Thomas Du  
 By driller performing actual drilling on site or contractor  
 Date 01-05-96

