WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50578
Permit No.
Basin 162

NOTICE OF INTENT NO. 16986

1. OWNER Cliff Anderson
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4701 E Cheyene

2. LOCATION SW ¼ SE ¼ Sec. 20 T. 21S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) 45-303-10 (Parcel No.) Green Saddle Ranch (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Calichie		3	5	2
Clay		5	12	7
Calichie		12	14	2
Clay		14	26	12
Calichie		26	29	3
Clay		29	44	15
Calichie		44	47	3
Clay		47	56	9
Calichie	WB	56	71	15
Clay		71	79	8
Calichie	WB	79	82	3
Clay		82	94	12
Calichie	WB	94	96	2
Clay		96	106	10
Calichie	WB	106	108	2
Clay		108	119	11
Calichie	WB	119	122	3
~~Clay~~		~~122~~		
Limestone	WB	123	128	5
Clay		128	133	5
Calichie	WB	133	136	3
Clay		136	140	4

LAS VEGAS OFFICE
DCNR/DWR
Received
JAN 12 1996

Date started December 11, 1995
Date completed December 13, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw cut
Size perforation 1/8" x 3"
From feet to feet
From 120 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box 4220 (Contractor)
Pahrump, NV 89041-4220
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 12/16/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627