WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

50582

OFFICE USE ONLY
Log No. 50582
Permit No.
Basin 162

NOTICE OF INTENT NO. 16981

1. OWNER Anna Chapman
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4361 Turner

2. LOCATION NE ¼ NW ¼ Sec. 29 T. 21S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) 45-321-05 (Parcel No.) Green Saddle Ranch (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	5
Calichie		5	9	4
Clay		9	16	7
Calichie		16	18	2
Clay		18	29	11
Calichie		29	31	2
Clay		31	42	11
Calichie		42	45	3
Clay		45	56	11
Calichie	WB	56	58	2
Clay		58	67	9
Calichie	WB	67	70	3
Clay		70	81	11
Calichie	WB	81	83	2
Clay		83	92	9
Calichie	WB	92	95	3
Clay		95	102	7
Calichie	WB	102	106	4
Clay		106	113	7
Calichie	WB	113	117	4
Clay		117	128	11
Calichie	WB	128	131	3
Clay		131	137	6
Calichie	WB	137	140	3

DCNR/DWR Received JAN 12 1996 LAS VEGAS OFFICE

Date started December 4, 1995
Date completed December 6, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 18" x 3"
From feet to feet
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 56 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box 4220 (Contractor)
Pahrump, NV. 89041-4220
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 12/12/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627