WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50602
Permit No.
Basin 72

NOTICE OF INTENT NO. 30757

1. OWNER Pegasus Gold Corp.
MAILING ADDRESS P. O. Box 330
Imlay, NV 89418

ADDRESS AT WELL LOCATION Florida Canyon Mine
South of Humboldt Exit 138, I-80

2. LOCATION NW ¼ NW 8E ¼ Sec. 34 T. 32 31 N/S R. 33 E. Pershing County
PERMIT NO. M/O 973 (Issued by Water Resources) 8-580-00 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| #11 Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 2 | 2 |
| Boulders/cobbles | | 2 | 20 | 18 |
| Gravel | | 20 | 35 | 15 |
| Siltstone | | 35 | 70 | 35 |
| Course gravel | | 70 | 95 | 25 |
| Med. gravel | | 95 | 115 | 20 |
| Course gravel | | 115 | 145 | 30 |
| Gravel/sand | X | 145 | 250 | 105 |

Monument set in 10' cement seal.

RECEIVED SEP 1 1995 STATE ENGINEER

Date started August 23, 19 95
Date completed August 24, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 5 | | 2 |

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | | 0 Feet | 250 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 5 | | Sch 80 | +2 | 250 |

Perforations:
Type perforation Slot
Size perforation .020
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 200
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 200 feet to 250 feet

Seal Type:
☐ Neat Cement
☐ Cement Grout
☐ Concrete Grout
xbentonite grout

9. WATER LEVEL
Static water level 190 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. (Contractor)
Address P. O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995
Signed (By driller performing actual drilling on site or contractor)
Date 9-5-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627