

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15693

1. OWNER Restoration Minerals Co ADDRESS AT WELL LOCATION None
 MAILING ADDRESS PO Box 115
Winnemucca NV 89446
 2. LOCATION SE 1/4 SE 1/4 Sec 14 T 30N N/S R 38 E Pershing County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Dense Basalt	None	5	95	90
Ambogudial Basalt	None	95	125	30
Dense Basalt	None	125	185	60
Ambogudial Basalt	Yes	185	265	80
Gravel	Yes	265	305	40
Andesite Flow	None	305	325	20
Gravel + some clay	Yes	325	365	40
Clay	None	365	400	35
Neat Cement sand		+2	62	62
		62	400	338

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 380 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 20 Feet
5 7/8 Inches 20 Feet 400 Feet
5 7/8 Inches 20 Feet 380 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1 1/4</u>		<u>SCH 80 steel</u>	<u>+2</u>	<u>380</u>
<u>6</u>		<u>1/8" wall</u>	<u>+2</u>	<u>20</u>

Perforations:
 Type perforation Vertical
 Size perforation 0.10
 From 2 feet to 100' blank feet
 From 100 feet to 380' slotted feet
 From 380 feet to 380' blank feet
 From 380 feet to 400 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 62' Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 62 feet to 400' feet

9. WATER LEVEL
 Static water level 121 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 57 °F Quality Unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EKLUND DRILLING COMPANY, INC Contractor
 Address P. O. Box 2786 Contractor
Elko, NV 89803
 Nevada contractor's license number 0030823
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1957
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 2-8-26-95

Date started 7-27 1995
 Date completed 7-29 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>400'</u>	<u>50</u>	<u>20</u>
			<u>1 hr</u>