

OFFICE USE ONLY  
 Log No. 50615  
 Permit No. 139  
 Basin 139

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT 30774

1. OWNER JARBIDGE WATER USERS ASSOC ADDRESS AT WELL LOCATION: Jarbridge, Nevada  
 MAILING ADDRESS P.O. Box 260050  
Jarbridge, NV 89826

2. LOCATION NE 1/4 SE 1/4 Sec. 17 T 46 S R 58 E Elko County  
 PERMIT NO. \_\_\_\_\_ Tract of Land \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Gravel & Boulders	X	3	35	32
Red brown volcanic rock		35	88	53
Gravel	X	88	110	22
Red brown volcanic rock		110	160	50
Fractured volcanic rock & sand	X	160	220	60

Pumped weighted bentonite slurry from 220 ft. up to 50 ft.

Pumped cement from 50 ft. to surface

8. WELL CONSTRUCTION

Depth Drilled 220 Feet Depth Cased not cased

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
10"	0	20	0	20
8"	20	60	20	60
6"	60	220	60	220

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started September 8, 1995  
 Date completed September 12, 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow test 200		1 hr.

9. WATER LEVEL

Static water level 4' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. Contractor  
 Address P.O. Box 850 Contractor  
Elko, NV 89803  
 Nevada contractor's license number issued by the State Contractor's Board 020582  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654

Signed John C. Davis  
 By driller performing actual drilling on site or contractor  
 Date 9/28/95

RECEIVED  
 9500710 AM 10:30  
 STATE ENGINEERS OFFICE

