

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK MW-2

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30767

1. OWNER TETRA TECH ADDRESS AT WELL LOCATION LDS Church in
MAILING ADDRESS 1555 W 2200 S Ste B Owyhee, NV
Salt Lake City, UT 84119

2. LOCATION NW 1/4 NE 1/4 Sec. 26 T 47 Q/S R. 52 E. Elko County
PERMIT NO. M/O 958 MW-2 Tract of Land
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	3"	3"
Gravel & Boulders		3"	6	5' 9"
Brown Clay		6	43	37
Fractured Volcanic		43	60	17
Volcanic Rock with				
Clay seams	X	60	115	55
Fractured Volcanic	X	115	140	25
Bentonite seal form		105-108'	3/8"	chips
Bentonite slurry		50-105'		

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 136'9" Feet

HOLE DIAMETER (BIT SIZE)
From To
8 Inches 0 Feet 60 Feet
6 1/2 Inches 60 Feet 140 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	Sch 40	0	136'9"

Perforations:
Type perforation slot
Size perforation .020
From feet to feet
From 116'9" feet to 136'9" feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 108 feet to 136'9" feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. Contractor
Address P.O. Box 850 Contractor
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1654
Signed John C. Davis
By driller performing actual drilling on site or contractor
Date 9-27-95

Date started 9-14, 1995
Date completed 9-15, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5		

RECEIVED
25 OCT - 2 PM 3:14
STATE ENGINEERS OFFICE