

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30771

1. OWNER Indian Health Services ADDRESS AT WELL LOCATION Near hospital in Owyhee
 MAILING ADDRESS Nevada Highway 225
Owyhee, Nevada 89832

2. LOCATION NW 1/4 NE 1/4 Sec 26 T. 46 ON/S R 52 E Elko County
 PERMIT NO. M/O-942 Well MW-8 Duck Valley Indial Res. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	4''	4''
Gravel		4''	3'	2'8''
Rock w/ clay seams		3	17	14
Yellow Clay		17	18	1
Clay & Fractured rock wet		18	24	6
Red/Brown rock & clay		24	46	22
Red/Brown Frac rock		46	55	9

Set 1st PVC to 55' - sandpack with silica sand from 31-55 - placed 3/8 bentonite seal from 26-31' - Set 2nd PVC from 0-25' - sandpacked with silica sand from 10-25' - placed 3/8 bentonite seal from 5-10' - cement from 5' to surface - set vault flush with asphalt

8. WELL CONSTRUCTION
 Depth Drilled 55 Feet Depth Cased 55 Feet

HOLE DIAMETER (BIT SIZE)
 From To
8 Inches 0 Feet 10 Feet
6 1/2 Inches 10 Feet 55 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>55</u>
<u>2</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>25</u>

Perforations:
 Type perforation millslot
 Size perforation .020
 From 40 feet to 55 feet
 From 15 feet to 25 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 5' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From see log feet to see log feet

9. WATER LEVEL
 Static water level: unknown feet below land surface
 Artesian flow: _____ G.P.M. _____ P.S.I.
 Water temperature: _____ °F Quality: _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Hackworth Drilling, Inc. Contractor
 Address P.O. Box 850 Contractor
Elko, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board: 020582
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1654
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 10-6-95

Date started 9-19, 1995
 Date completed 9-19, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 95 OCT 10 AM 10:30
 STATE ENGINEERS OFFICE