

OFFICE USE ONLY  
 Log No. 50640  
 Permit No. 57552  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12386

1. OWNER COULTER CONSTRUCTION ADDRESS AT WELL LOCATION ROSADA + DAPPLE GREY  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION N1/4 SW 1/4 Sec. 32 T. 19 N/S R. 60 E. CLARK County  
 PERMIT NO. 57552 125-32-301-009  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND + ROCKS		0	10	10
SMT GRAVEL w/		10	140	130
STRKS SANDSTONE				
CLAY		140	170	30
SMT GRAVEL w/		170	340	170
STRKS SANDSTONE				
SMT GRAVEL w/	360	340	500	160
CLAY STRINGERS				


8. WELL CONSTRUCTION  
 Depth Drilled 500 Feet Depth Cased 500 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 500 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>+1</u>	<u>500</u>

Perforations:  
 Type perforation FACTORY SAW  
 Size perforation 1 1/8 x 2 1/2  
 From 460 feet to 480 feet  
 From 420 feet to 440 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 500 feet



Date started 2-1, 1996  
 Date completed 2-8, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 285 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name DESERT DRILLING Contractor  
 Address 6475 GARY AVE Contractor  
LAS VEGAS, NV. 89139  
 Nevada contractor's license number issued by the State Contractor's Board 34274  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1966  
 Signed Timdall Couch  
 By driller performing actual drilling on site or contractor  
 Date 2-17-96