WHITE—DIVISION OF WATER RESOURCES
PINK—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50651
Permit No.
Basin

NOTICE OF INTENT NO. 20603

Well #2

1. OWNER Joe Fallini
MAILING ADDRESS Twin Springs Ranch
vai Tonopah, NV 89049

ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NE ¼ Sec. 13 T. 5 N. R. 50 E. Nye County
PERMIT NO. 59707 (Issued by Water Resources) 9 071 02 (Parcel No.) NORTH (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Drilled previously | | 0 | 67 | |
| Sand & gravel | | 67 | 95 | 18 |
| LIghtly cemented s & g | | 95 | 115 | 20 |
| Gravle stringers & brown clay | | 115 | 410 | 295 |

Date started May 8 ~~April 20~~, 19 95
Date completed May 14 ~~May 5~~, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 250 | | 6 |

8. WELL CONSTRUCTION
Depth Drilled 410 Feet Depth Cased 395 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 40 Inches | 75 Feet | 410 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 30 | 98.93 | 5/16 | +2 | 395 |

Perforations:
Type perforation Torch cut
Size perforation 1/8"
From 100 feet to 395 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 67
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 410 feet

9. WATER LEVEL
Static water level 76 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSOIN DRILLING CO., INC. (Contractor)
Address 4185 West Harmon (Contractor)
Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1734
Signed Richard K. Thompson (By driller performing actual drilling on site or contractor)
Date June 7, 1995

'95 JUN 12 P12:05
STATE ENGINEER'S OFFICE

DCNR/DWR Received JUN 22 1995 LAS VEGAS OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (D)-627