WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50653
Permit No.
Basin

NOTICE OF INTENT NO. 28549

1. OWNER Lee Drilling Inc
MAILING ADDRESS PO Box 519
Beatty, NV 89003

ADDRESS AT WELL LOCATION Nye County near Beatty, Nevada

2. LOCATION SE ¼ SW ¼ Sec. 2 T. 11 N/S R. 46 E. NYE County
PERMIT NO. MO 931 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	7	7
Shale		7	27	27
Basalt		27	355	328
Tuff		355	445	90
Basalt		445	470	25
Tuff		470	610	140
Basalt		610	640	30
Tuff		640	675	35
Basalt		675	680	5
Tuff		680	795	115
Basalt		795	800	5
Tuff		800	1200	400

Date started 5-18, 1995
Date completed 5-21, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1000	5	During Drill
1200	10	1½ hr

8. WELL CONSTRUCTION
Depth Drilled 1200 Feet Depth Cased 1198' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	18 Feet
5 3/4 Inches		18 Feet	1200 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		18"	18	+2
1½"		Sch 40 PVC	1200	700
1½"		Sch 40 Pipe	700	+2

Perforations:
Type perforation SCREEN
Size perforation .020
From SCREEN 1200 feet to 700 feet
From BLANK 700 feet to +2 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 1200 feet to 50' feet

9. WATER LEVEL
Static water level 385 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EKLUND Drilling Company, INC (Contractor)
Address P.O. Box 2786 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1942
Signed William Riley (By driller performing actual drilling on site or contractor)
Date 5-25-95

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627