DW-5

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50657
Permit No.
Basin 061

NOTICE OF INTENT NO. 32735

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
DEE GOLD MINE

2. LOCATION NE ¼ NE ¼ Sec. 4 T. 36 N S R. 49 E. EUREKA County
PERMIT NO. 57073 T (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ORIGINAL DEPTH			1,660	
FRACTURED BLACK ROCK		1,660		
WITH CALCITE			1,880	220
HARD BLACK ROCK		1,880	2,050	170
FRACTURED BLACK ROCK		2,050		
WITH CALCITE			2,110	60
HARD BLACK ROCK		2,110	2,120	10
FRACTURED BLACK ROCK		2,120		
WITH CALCITE			2,130	10
HARD BLACK ROCK		2,130	2,255	125
FRACTURED BLACK ROCK		2,255		
WITH CALCITE			2,340	85

Date started SEPTEMBER 3, 19 95
Date completed SEPTEMBER 13, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 2340 Feet Depth Cased 1642 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
31 Inches		0 Feet	40 Feet
22 Inches		40 Feet	600 Feet
~~17-1/2~~ Inches		~~600~~ Feet	~~1,660~~ Feet
~~12~~ Inches		~~1,660~~ Feet	~~2,340~~ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24	95	.375	0	40
18	71	.375	0	600
~~12~~	~~50~~	~~.375~~	~~0~~	~~1,432~~
~~12~~	~~50~~	~~.375~~	~~1,632~~	~~1,642~~

Perforations:
Type perforation LOUVERED
Size perforation 3/16 BY 2-1/2
From 1,432 feet to 1,632 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 1,660 feet

9. WATER LEVEL
Static water level 1,478 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 115 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2000

Signed WILLIAM EDDY William Eddy
(By driller performing actual drilling on site or contractor)

Date SEPTEMBER 26, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627