PPW-73

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50659
Permit No.
Basin 061

NOTICE OF INTENT NO. 28576

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NE ¼ SE ¼ Sec. 19 T 36 ☒ S R 50 E EUREKA County
PERMIT NO. 61248 T (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAY ROCK		0	40	40
GRAY & BLACK ROCK		40	85	45
BROWN & BLACK ROCK		85	100	15
BROWN ROCK WITH CLAY		100	240	140
GRAY ROCK WITH CLAY		240	275	35
BROWN CLAY		275	295	20
BROWN CLAY WITH GRAY GRAVEL		295	325	30
BROWN CLAY WITH BLACK ROCK		325	330	5
BROWN CLAY & GRAVEL		330	360	30
BROWN CLAY		360	440	80
BROWN CLAY WITH BLACK ROCK		440	545	105
GRAY ROCK WITH GRAY CLAY		545	575	30

Date started SEPTEMBER 10, 1995
Date completed SEPTEMBER 15, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 575 Feet Depth Cased 560 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
19 Inches	0 Feet	75 Feet
12-1/4 Inches	75 Feet	575 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	54.57	.375	0	75
6	17.02	.250	0	75

Perforations:
Type perforation LOUVERED
Size perforation .125
From 75 feet to 560 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 575 feet

9. WATER LEVEL
Static water level 133 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 58 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1800
Signed VICTOR HERNANDEZ Victor Hernandez
By driller performing actual drilling on site or contractor
Date SEPTEMBER 26, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627