PPW-71

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50660
Permit No.
Basin 01

NOTICE OF INTENT NO. 29628

1. OWNER Barrick Goldstrike
MAILING ADDRESS P.O. Box 29
Elko, NV 89801

ADDRESS AT WELL LOCATION
Barrick Goldstrike Mine

2. LOCATION NE ¼ NE ¼ Sec. 30 T. 36 N/S R. 50 E. Eureka County
PERMIT NO. 61248T (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	10	10
Clay		10	50	40
Rock & clay		50	120	70
Clay		120	150	30
Rock & clay		150	230	80
Clay		230	250	20
Rock & Clay		250	290	40
Gray rock		290	340	50
Gray rock & clay		340	560	220
Black rock		560	670	110
Rock & clay		670	870	200

Date started August 9, 1995
Date completed August 19, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 870 Feet Depth Cased 800 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
21 Inches		0 Feet	40 Feet
12 1/4 Inches		40 Feet	870 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	63	.375	0	40
8	22	.250	0	120

Perforations:
Type perforation Louvered
Size perforation .128
From 120 feet to 800 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 870 feet

9. WATER LEVEL
Static water level 249 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 60 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address 2286 West 1500 South (Contractor)
Salt Lake City, UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1800

Signed Victor Hernandez (By driller performing actual drilling on site or contractor)
Date 09-07-95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627