PPW-72

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50664
Permit No.
Basin 01

NOTICE OF INTENT NO. 28577

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NE ¼ NE ¼ Sec. 30 T. 36 N/S R. 50 E. EUREKA County
PERMIT NO. 61248 T (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BLACK ROCK & GRAY CLAY		0	70	70
BROWN ROCK & CLAY		70	130	60
GRAY ROCK		130	145	15
BROWN CLAY & BLACK ROCK		145	200	55
GRAY CLAY & BLACK ROCK		200	305	105
HARD BLACK ROCK		305	315	10
REDDISH BROWN CLAY		315	435	120
GRAY & RED CLAY		435	520	85
GRAY ROCK & CLAY		520	535	15
RED CLAY & ROCK		535	550	15
RED ROCK & CLAY		550	580	30
BLACK CLAY		580	595	15
RED CLAY & ROCK		595	600	5
GRAY & RED ROCK WITH CLAY		600	695	95
BROWN ROCK		695	705	10
GRAY CLAY & ROCK		705	900	195
BLACK ROCK		900	1,015	115

Date started SEPTEMBER 10, 19 95
Date completed SEPTEMBER 20, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1,015 Feet Depth Cased 1,000 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
19 Inches	0 Feet	40 Feet
12-1/4 Inches	40 Feet	1,015 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	54.57	.375	0	40
6	17.02	.250	0	60

Perforations:
Type perforation LOUVERED
Size perforation .125
From 60 feet to 1,000 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 1,015 feet

9. WATER LEVEL
Static water level 616 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 65 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1800
Signed VICTOR HERNANDEZ Victor Hernandez
By driller performing actual drilling on site or contractor
Date SEPTEMBER 26, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627