

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28949

1. OWNER Brian Andreozzi ADDRESS AT WELL LOCATION FRONTIER + 2ND
 MAILING ADDRESS Hc 34 293-1 Lot 13 Block 35
Ryndon Elko 89801
 2. LOCATION SE 1/4 NW 1/4 Sec. 6 T. 35 N/S R. 57 E Elko County
 PERMIT NO. 30-035-133 Parcel No. Ryndon Subdivision Name MOR #1
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
loam		0	3	3
Hard PAN		3	19	16
Gravel	X	19	29	10
Clay		29	36	7
Cemented Gravel		36	87	51
SOFT SANDSTONE		87	106	19
Cemented Gravel		106	112	6
SOFT SANDSTONE	X	112	116	4
Cemented Gravel		116	120	4

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>188</u>	<u>72</u>	<u>120</u>

Perforations:
 Type perforation slots
 Size perforation 3/16 x 3"
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 120 feet

9. WATER LEVEL
 Static water level 19 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

Date started 9-14, 1995
 Date completed 9-15, 1995

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30 +</u>		<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fentig Drilling Co Contractor
 Address P.O. Box 525 Contractor
Elko NV 89801
 Nevada contractor's license number issued by the State Contractor's Board 31904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Shane C Fentig
 By driller performing actual drilling on site or contractor
 Date 9-26-95