

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28110

1. OWNER Richard Harris ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 114 S Palomar Tucson, Arizona 85711 8 miles North West of Golconda
2. LOCATION NW 1/4 NW 1/4 Sec 5 T 36 N 41 E Humboldt County
PERMIT NO. Domestic Parcel No. N/A Subdivision Name _____
Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Big Rocks Sand + Gravel		0	40	40
Sand Gravel + Clay		40	200	160
Red Clay Sand + Gravel		200	220	20
Purple Clay Sand + Gravel		220	260	40
Chert Layer		260	262	2
Sand + Gravel	X	262	270	8
Chert Layer		270	273	3
SAND + Gravel	X	273	278	5
Chert Layer		278	281	3
SAND Gravel	X	281	293	12
Chert Layer		293	295	2
SAND + Gravel	X	295	300	5

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 295 Feet
HOLE DIAMETER (BIT SIZE)
From To
10.625 Inches 0 Feet 120 Feet
6.125 Inches 120 Feet 300 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12	.188	+1	120
5.562	10	.188	110	295

Perforations:
Type perforation FACTORY Saw Cuts
Size perforation 3/32
From 100 feet to 120 feet
From 275 feet to 295 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 60 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 60 feet to 120 feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow NO G.P.M. 6 P.S.I.
Water temperature 60.1 °F Quality Good

Date started 5-8-95 1995
Date completed 5-10-95 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FRED ANDERSON Contractor
Address 10760 Grass Valley Road Winnemucca, NV 89445 Contractor
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 5-10-95