WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 586094
Permit No.
Basin

NOTICE OF INTENT NO. 16894

1. OWNER Dozella Serrani
MAILING ADDRESS 901 W. Ember
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
Ember St./Pahrump

2. LOCATION SW ¼ SW ¼ Sec. 33 T. 20S N/S R. 53 E County
PERMIT NO. (Issued by Water Resources) 35-542-07 (Parcel No.) Palo Verde Ranchos (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Soil		0	12	12
Dec Calichia		12	24	12
Hard Calichia		24	27	3
Grey Clay	x	27	58	31
Hard Calichia	x	58	62	4
Grey Clay	x	62	102	40
Brown Clay	x	102	120	18
Grey Clay	x	120	140	40

DCNR/DWR Received JAN 22 1996 Las Vegas Office

Date started December 26, 19 95
Date completed December 28, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	Na	½

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
Type perforation Torch
Size perforation ¼ x 6
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 90 90 feet to 120 140 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry Jenkins (Contractor)
Address P.O. Box 3392 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Larry Jenkins (By driller performing actual drilling on site or contractor)
Date 1-10-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627