


OFFICE USE ONLY
 Log No. 50698
 Permit No. _____
 Basin. 160



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16892

1. OWNER Bob Noyes ADDRESS AT WELL LOCATION Kingston Ave/Pahrump
 MAILING ADDRESS Kingston Ave. Pahrump, NV 89041

2. LOCATION SW 1/4 NE 1/4 Sec. 16 T. 19S N/S R. 53 E Nye County Nye
 PERMIT NO. 29-215-10 Country Place II
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Soil		0	12	12
Dec Calichia		12	21	9
Hard Calichia		21	27	6
Grey Clay		27	39	12
Calichia		39	42	3
Grey Clay	x	42	59	17
Brown Clay	x	59	72	13
Grey Clay	x	72	87	15
Calichia	x	87	107	20
Brown Clay	x	107	135	28
Grey Clay	x	135	154	19
Brown Clay	x	154	172	18
Calichia	x	172	185	13
Grey Clay	x	185	192	7
Brown Clay	x	192	200	8

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	200

Perforations:
 Type perforation Torch
 Size perforation 1/2" x 6
 From 160 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 150 feet to 200 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Good

Date started January 5 1996
 Date completed January 6 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>na</u>	<u>1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Larry Jenkins Contractor
 Address P.O. Box 3392 Pahrump, NV 89041 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0035901
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916

Signed Larry Jenkins
 By driller performing actual drilling on site or contractor
 Date 1-5-96