WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50756
Permit No.
Basin 012 B

NOTICE OF INTENT NO. 32578

1. OWNER PAUL & JUNE HOFMANN
MAILING ADDRESS 855 Hoge Road
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 395 N & Stead Blvd (NW of freeway)
Reno, Nevada 89506

2. LOCATION SE ¼ SE ¼ Sec. 4 T. 20N N/S R. 19E E. Washoe County
PERMIT NO. (Issued by Water Resources) 090-150-06 (Parcel No.) Stead Area, by freeway (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay w/small boulders & gravels		1	6	5
Brown clay w/gravels		6	38	32
Brown sandy clay		38	69	31
Brown clay		69	82	13
Soft zone (app. 5 GPM)	X	82	90	8
Brown sandy clay		90	110	20
Soft zone (app. 5 GPM)	X	110	116	6
Brown sandy clay with gravels		116	127	11

Date started 11-8-95, 19
Date completed 11-9-95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		

8. WELL CONSTRUCTION
Depth Drilled 127 Feet Depth Cased 127 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	127 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	127

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 79 feet to 119 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 foot
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 127 feet

9. WATER LEVEL
Static water level 37 feet below land surface
Artesian flow G.P.M. 10 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date November 13, 1995

RECEIVED 1995 NOV 15 AM 11:07 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627