WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50769
Permit No.
Basin 076

NOTICE OF INTENT NO. 30660

1. OWNER Dennis Pennington
MAILING ADDRESS

ADDRESS AT WELL LOCATION 865 Wood Church Rd Fernley NV

2. LOCATION SE ¼ SE ¼ Sec. 10 T. 20 N/S R 24 E [signature] County
PERMIT NO. N/A (Issued by Water Resources) 20-151-09 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, Soil		0	6	6
Sand, Clay		6	13	7
Sand (Course & Fine)		13	58	45
Clay, Fine Sand		58	89	31
Clay (Biege)		89	104	15
Sand, Course & Fine)		104	114	10
Clay (Biege)		114	138	24
Clay (Grey)		138	152	14
Sand Course & Fine	170	152	170	28
Course Sand & Gravels 3/8 minus	199	170	199	29

RECEIVED 95 NOV -1 PM 12:45 STATE ENGINEER'S OFFICE

Date started 10/16/95, 19
Date completed 10/17/95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
85-90		2½ hrs

8. WELL CONSTRUCTION
Depth Drilled 199 Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	199 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.	1.88	+1	199

Perforations:
Type perforation Torch Cut
Size perforation 3/16 x 6" x 6" 1000 pcs
From 190' feet to 198 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60' feet to 199' feet

9. WATER LEVEL
Static water level 68' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality V-Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Peach Drilling Inc (Contractor)
Address PO 599 (Contractor)
S.S. NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed [signature] By driller performing actual drilling on site or contractor
Date 10/28/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

I