

OFFICE USE ONLY
 Log No. 50779
 Permit No. 084
 Basin 084

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32573 Bailey
Paul Parker Jarred & Karla
Hidden Creek Road 22000 Whiskey Spgs. Rd.

1. Consultant: GROUNDWATER RESOURCES CONSULTANTS Owner: AT WELL LOCATION
 MAILING ADDRESS: 6200 E. 14th Street, Suite A200 Tucson, AZ 85711
 2. LOCATION SW 1/4 SW 1/4 Sec. 12 T. 22N N/S R. 21 E. Washoe County
 PERMIT NO. AREA D 077-110-22 Parcel No. Palomino Valley Unit 1 Subdivision Name 12.2.1.1 pas. 4

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Reddish brown sandy clays		1	7	6
Gray hard volcanic rock		7	30	23
Purple volcanic rock		30	35	5
Reddish brown volcanic rock		35	54	19
Red volcanic rock		54	90	36
Moist red clay		90	91	1
Red volcanic rock		91	137	46
Fracture (app 1 GPM)	X	137	138	1
Red volcanic rock		138	155	17
Reddish brown volcanic rock		155	219	64
Soft zone (NO WATER)		219	227	8
Brown volcanic rock		227	247	20
Soft fracture rock (app 3 GPM)	X	247	280	33
Brown volcanic rock		280	286	6
Gray volcanic rock, clay streaks		286	327	41
Soft zone (NO WATER)		327	328	1
Gray volcanic rock		328	383	55
Green volcanic rock		383	441	58
Soft zone (NO WATER)		441	442	1
Green volcanic rock		442	461	19
Soft zone (NO WATER)		461	466	5
Green volcanic rock with clay streaks		466	490	24

8. WELL CONSTRUCTION
 Depth Drilled 550 Feet Depth Cased 550 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 550 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	550

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 205 feet to 285 feet
 From 365 feet to 385 feet
 From 445 feet to 465 feet
 From 525 feet to 545 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50 feet
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 550 feet

9. WATER LEVEL
 Static water level 72 feet below land surface
 Artesian flow _____ G.P.M. 4 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature] by driller performing actual drilling on site or contractor
 Date October 19, 1995

cont page 2
 Date started 10-13-95
 Date completed 10-17-95

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>4</u>		

