

OFFICE USE ONLY  
 Log No. 50722  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31867

1. OWNER Anne & Jasper Ferguson ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 6776 Honeysuckle drive 16130 Red Rock Road  
Reno, Nevada 89506 Reno, Nevada 89506

2. LOCATION NE 1/4 SE 1/4 Sec 9 T.23N N/S R.18 E Washoe County  
 PERMIT NO. 078-162-02 Rancho Haven  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tan Yellow Brown with Tan clay		0	29	
Tan Yellow Brown White coarse gravel		29	42	
Brown yellow White semi decomposed granite		42	68	
Sticky Tan Clay		68	72	
Coarse Tan Yellow White D.G.		72	84	
Hand Black & White Granite		84	118	
Coarse Brown Yellow White Sands & Gravels		118	124	
Hard & Fractured Black White Brown Granite		124	200	
200 T.D.				

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10-5/8 Inches To 0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	+ 1-1/2	200

Perforations:  
 Type perforation Factory Sawn  
 Size perforation 3/32 x 3"  
 From 180 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 101  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 200 feet to 101 feet

Date started November 3 1995  
 Date completed November 7 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15+		3

9. WATER LEVEL  
 Static water level 65 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. Pump & Well Service, Inc. Contractor  
 Address 1800 1/2 Frazer Avenue Contractor  
Sparks, Nevada 89431  
 Nevada contractor's license number issued by the State Contractor's Board 35387-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511  
 Signed Larry Welch  
 By driller performing actual drilling on site or contractor  
 Date November 9, 1995