WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

DCNR/DWR Received OCT 30 1995 LAS VEGAS OFFICE

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50807
Permit No.
Basin 212

NOTICE OF INTENT NO. 9355

1. OWNER HLA
MAILING ADDRESS 4170 S. Decatur LV NV 89103
ADDRESS AT WELL LOCATION 1928 N. Como

2. LOCATION NW ¼ SW ¼ Sec. 5 T. 20 N/S R. 62 E. Clark County
PERMIT NO. MD-2572 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Plug

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	20	
Caliche		20	24	
Clay w/sand				
Fine S		24	45	

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8	0	45

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2-5	PVC	Sch 40	0	30

Perforations:
Type perforation .020 S/6 Hole Screen
Size perforation
From 30 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 38
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 30 feet to 45 feet

9. WATER LEVEL
Static water level 38 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Weber Environmental Inc (Contractor)
Address 4381 S. Valley View #31 (Contractor)
LV NV 89103
Nevada contractor's license number issued by the State Contractor's Board CO 39508
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1847
Signed (By driller performing actual drilling on site or contractor)
Date 10-12-95

Date started 5-6, 1995
Date completed 5-6, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627