




WHITE-DIVISION OF WATER RESOURCES  
 CANARY-CLIENT'S COPY  
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES



OFFICE USE ONLY

Lot No. 50815  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14743

1. OWNER U.S. AIR FORCE WFC/SOR ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 4551 DUBLIN DR NEVADA AFB INDIAN SPRINGS  
NEVADA AFB, NV 89191-6542  
 2. LOCATION 1/4 NW 1/4 Sec. 38 T. 16 N. 8R. 56 E. CLARKE County \_\_\_\_\_  
 PERMIT NO. MO-2597 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other None

6. LITHOLOGIC LOG


Material	Water Strata	From	To	Thick-ness
<u>clay</u>		<u>0</u>	<u>10</u>	
<u>clay w/ gravel</u>		<u>10</u>	<u>14</u>	
<u>clay w/ sand</u>		<u>14</u>	<u>26</u>	
<u>clay w/ fine</u>		<u>26</u>	<u>40</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 40 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 2 1/4 Inches To 40 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2-5</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>10</u>

Perforations:  
 Type perforation slotted screen  
 Size perforation .075  
 From 10 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 7  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 40 feet to 7 feet



Date started 5-18, 1995  
 Date completed 5-18, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 15 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge. **I**  
 Name Weber Environmental Contractor  
 Address 4301 S Jolly View #21 Contractor  
LV NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 0039528  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: M1947  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 6-20-95