

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **12055**

1. OWNER Elisabeth Pearson ADDRESS AT WELL LOCATION 1600 S. Decatur
MAILING ADDRESS 6850 E. Pearson
2. LOCATION NV 1/4 Sec 25 T 20 N0R 60 E Clark County
PERMIT NO. MO-2709 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. Domestic Municipal/Industrial
 Irrigation Test Cable Rotary RVC
 Monitor Stock Air Other Hydr

6. LITHOLOGIC LOG
Material Water Strata From To Thickness
CLAY 0 5
CAILDS 5 12
clay w/ fine fines 12 25

8. WELL CONSTRUCTION
Depth Drilled 25 Feet HOLE DIAMETER (BIT SIZE) From To
8 Inches 0 Feet 25 Feet
Inches Feet
Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.5</u>	<u>110</u>	<u>0.40</u>	<u>0</u>	<u>25</u>

Perforations: slotted screens
Type perforation 020
Size perforation 23 feet to 25 feet
From 0 feet to 25 feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 20 Pumped Concrete GROUT
Placement Method: Poured

Gravel Packed: Yes No
From 22 feet to 25 feet

9. WATER LEVEL
Static water level 13 feet below land surface
Artesian flow 0 G.P.M. P.S.I.
Water temperature 0 °F Quality 0

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wesley Cunningham Contractor
Address 4351 S. Valley View #21 Contractor
LU NV 89103

Nevada contractor's license number 0038528
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources the onsite driller 12181477

Signed [Signature]
Date 10-13-95
By driller performing actual drilling on site or contractor

7. WELL TEST DATA
TEST METHOD: Bailor Pump Air Lift
G.P.M. Draw Down (Feet Below Static) Time (Hours)

Date started 9-10 19 95
Date completed 9-10 19 95