WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

CASEY ANDERSON WELL
STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50851
Permit No.
Basin 49

NOTICE OF INTENT NO. 31145

1. OWNER Pruitt Realty
MAILING ADDRESS Adobe Heights 163 12th Street Elko, NV 89801

ADDRESS AT WELL LOCATION South side of Adobe Heights Road

2. LOCATION NE ¼ SW ¼ Sec. 1 T 34 N/S R 54 E Elko County
PERMIT NO. (Issued by Water Resources) 5-510-13 (Parcel No.) Special Lands- Adobe Heights (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Yellow clay		1	10	9
Firm volcanic		10	20	10
Yellow clay		20	55	35
Firm grey shale		55	470	415
Medium to firm shale w/siltstone layers		470	740	270

Date started November 6, 19 95
Date completed November 9, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		5

8. WELL CONSTRUCTION
Depth Drilled 740 Feet Depth Cased 735 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches	0 Feet	740 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1	735

Perforations:
Type perforation Millslot
Size perforation 3/16 x 3
From 715 feet to 695 feet
From 675 feet to 655 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal XX 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 735 feet to 50 feet

9. WATER LEVEL
Static water level 260 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board ~~1998~~ 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1998
Signed Bradley D. Wiesel (By driller performing actual drilling on site or contractor)
Date 11-17-95

RECEIVED 95 NOV 30 AM 11:31 ENGINEERING OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627