WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50853
Permit No.
Basin 177

NOTICE OF INTENT NO. 20527

1. OWNER Emerald Huldermon #2
MAILING ADDRESS 5463 Rutile St.
Riverside Calif 92509
ADDRESS AT WELL LOCATION Clover Valley
So. of Wells Nevada

2. LOCATION SE ¼ SW ¼ Sec. 5 T. 34 N/S R. 63 E. Elko County
PERMIT NO. 57821 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	1	
Decomposed Granite		1	30	
Brown Sandstone		30	40	
Grey Sandstone		40	75	
Granite		75	79	
Broken Rock	x	79	90	
Granite		90	100	
Fractured Rock		100	105	
Green Rock		105	130	
Hard Green Rock		130	133	
Broken		133	150	
Solid Green Rock		150	163	
layers soft & Solid Rock		163	240	
Pink colored Rock		240	300	

Date started May 2, 1993
Date completed June 1, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
16	Inches	Feet	Feet
12	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12"		.250	+1	120
10"		.250	160	190
8"		.250	190	300

Perforations:
Type perforation Factory Milled
Size perforation 3/16 x 3
From 55 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 300 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality unaltered

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of ~~my knowledge~~.
Name R.P. Reynolds (Contractor)
Address Wells, Nevada (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 019410
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1390
Signed (By driller performing actual drilling on site or contractor)
Date 8-20-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627