WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50858
Permit No.
Basin 49

NOTICE OF INTENT NO. 30778

1. OWNER K L Partnership
MAILING ADDRESS 609 Ash
Elko, NV 89801

ADDRESS AT WELL LOCATION S. side of 27th St.
between Osage & Crow Ave.

2. LOCATION SW ¼ NE ¼ Sec. 19 T 35 N/S R 56 E Elko County

PERMIT NO. (Issued by Water Resources) | Parcel No. 36-010-03 | Subdivision Name MVR #4

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel		0	7	7
Orange sandy clay		7	23	16
Cemented pea gravel & sand		23	110	87
Coarse gravel		110	118	8
Fine gravel & sand		118	165	47
Coarse gravel & sand X		165	200	35

RECEIVED 95 OCT 16 PM 3:18 STATE ENGINEERS OFFICE

Date started 10-3, 1995
Date completed 10-4, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
75		2

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
10 5/8 Inches	0 Feet	200 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1½	200

Perforations:
Type perforation millslot
Size perforation 3/16 X 3
From feet to feet
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 92 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-12-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627