WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50859
Permit No.
Basin 49

NOTICE OF INTENT NO. 30777

1. OWNER K L Partnership
MAILING ADDRESS 609 Ash
Elko, NV 89801

ADDRESS AT WELL LOCATION S. side of 26th St. between Blackfoot & Pueblo

2. LOCATION SW ¼ NW ¼ Sec. 19 T 35 N/S R 56 E Elko County

PERMIT NO. (Issued by Water Resources) | 36-013-02 (Parcel No.) | MVR #4 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Alluvium | | 0 | 6 | 6 |
| Brown siltstone | | 6 | 38 | 32 |
| Brown siltstone with pea gravel | | 38 | 215 | 177 |
| Red/Black volcanic rock-fractured | X | 215 | 260 | 45 |

RECEIVED 95 OCT 16 PM 3:17 STATE ENGINEERS OFFICE

Date started 10-3, 1995
Date completed 10-4, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 37 | | 1¼ |

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 260 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | .188 | +1½ | 260 |

Perforations:
Type perforation Millslot
Size perforation 3/16 X 3
From feet to feet
From feet to feet
From 240 feet to 260 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 166 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-12-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627