WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50860
Permit No.
Basin 49

NOTICE OF INTENT NO. 30779

1. OWNER K L Partnership
MAILING ADDRESS 609 Ash
Elko, NV 89801

ADDRESS AT WELL LOCATION S.E. Corner of 26th ST & Blackfoot Ave.

2. LOCATION SW ¼ NW ¼ Sec. 19 T. 35 N/S R. 56 E Elko County

PERMIT NO. (Issued by Water Resources) | Parcel No. 36-013-03 | Subdivision Name MVR #4

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	12	12
Brown siltstone		12	78	66
Brown siltstone & pea gravel		78	115	37
Coarse gravel & siltstone		115	140	25
Brown siltstone & pea gravel		140	230	90
Red/Black fractured volcanic	X	230	270	40

RECEIVED 95 OCT 16 PM 3:18 STATE ENGINEERS OFFICE

Date started 10-4, 19 95
Date completed 10-5, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		2

8. WELL CONSTRUCTION
Depth Drilled 270 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	270 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1½	270

Perforations:
Type perforation Millslot
Size perforation 3/16 X 3
From feet to feet
From 250 feet to 270 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 270 feet

9. WATER LEVEL
Static water level 185 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-12-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627