PPW-74

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 5086
Permit No.
Basin 61

NOTICE OF INTENT NO. 29504

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NEVADA 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SW ¼ NE ¼ Sec. 30 T. 36 (N)S R. 50 E. EUREKA County
PERMIT NO. 55150 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN ROCK		0	90	90
GRAY ROCK		90	105	15
BROWN ROCK		105	115	10
GRAY ROCK		115	145	30
BLACK ROCK & CLAY		145	150	5
GRAY ROCK & CLAY		150	210	60
BLACK & GRAY ROCK		210	475	265
GRAY ROCK & CLAY		475	670	195
GRAY, GREEN & WHITE ROCK		670	795	125
GRAY CLAY & ROCK		795	865	70
GRAY & BLACK ROCK		865	950	85

Date started SEPTEMBER 25, 19 95
Date completed OCTOBER 1, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 950 Feet Depth Cased 943 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
19 Inches	0 Feet	35 Feet
12-1/4 Inches	35 Feet	950 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	62.58	.375	+2	35
6	17.02	.250	+2	120

Perforations:
Type perforation LOUVERED
Size perforation 1/8"
From 120 feet to 943 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 950 feet

9. WATER LEVEL
Static water level 389 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 60 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1800
Signed VICTOR HERNANDEZ Victor Hernandez
(By driller performing actual drilling on site or contractor)
Date OCTOBER 11, 1995

(Rev. 3 91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627