WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1-B

OFFICE USE ONLY
Log No. 50885
Permit No. 58048
Basin 215

NOTICE OF INTENT NO. 15543

1. OWNER Oglebay Norton Corp
MAILING ADDRESS 1100 Superior Avenue Cleveland OHIO 44114
ADDRESS AT WELL LOCATION Gale Hills, NEVADA

2. LOCATION NE ¼ SW ¼ Sec. 8 T. 20 N/S R. 65 E. CLARK County
PERMIT NO. ~~[illegible]~~ 58048 (Issued by Water Resources) Parcel No. Subdivision Name ONCO

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☑ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil & Gypsum		0	13	13
gypsum		13	237	224
sand		237	530	293
sand, shale, clay		530	623	93
sand		623	724	101
sand-shale-clay		724	1055	331
sand		1055	1222	167
conglomerate		1222	1249	27
sand		1249	1270	21
sandy shale		1270	1285	15
conglomerate		1285	1290.5	5 1/2

Date started 4-26, 1995
Date completed 5-11, 1995

JUN 20 A11 25
RECEIVED
STATE ENGINEERS OFF

DCNR/DWR Received JUN 22 1995 LAS VEGAS OFFICE

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N/A	

8. WELL CONSTRUCTION
Depth Drilled 1290.5 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)
6 Inches From 0 Feet To 1290.5 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	2.5	Sch 80	0	1280

Perforations:
Type perforation Slotted
Size perforation 1/16
From 440 feet to 1280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 ~~[illegible]~~
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From N/A feet to feet

9. WATER LEVEL
Static water level 344.09 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 75 °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GUSTIN CORP (Contractor)
Address P.O. Box 894 (Contractor)
ELKO, NEVADA 89807
Nevada contractor's license number issued by the State Contractor's Board 0022193
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1821
Signed [signature] By driller performing actual drilling on site or contractor
Date 6-13-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627