WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50907
Permit No. 60765
Basin 162

NOTICE OF INTENT NO. 16626

1. OWNER David Stundon
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ SE ¼ Sec. 25 T. 21-S N/S R. 53 E Nye County
PERMIT NO. APN. 44-771-31 (Issued by Water Resources) 3 (Parcel No.) Permit # 60765 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Clay/ Caliche Balls		4	18	14
Hard Limestone		18	35	17
White Clay		35	60	25
Hard White Limstone		60	75	15
Grey Clay	x	75	104	29
Hard Limestone		104	113	9
Grey Clay	x	113	151	38
Hard Limestone		151	154	3
Brown Clay		154	174	20
Hard Lime		174	178	4
Brown Clay		178	240	62
Hard Clay		240	246	6
Brown Clay		246	288	42
Hard Formation		288	294	6
Brown Clay		294	300	6

Date started February 17, 19 96
Date completed March 8, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	300 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10	25 lbs.	.250	0	300

Perforations:
Type perforation Torch Cut
Size perforation ¼ in width 8 in long
From 220 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 41 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address HCR 77 Box 36525 (Contractor)
Nevada contractor's license number 7484 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg (By driller performing actual drilling on site or contractor)
Date March 10, 1996

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627