WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50914
Permit No.
Basin 162

NOTICE OF INTENT NO. 15041

1. OWNER Mary Sauers
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4231 Medicine Man

2. LOCATION NE ¼ SE ¼ Sec. 14 T. 20 S N/S R 52 E Nye County
PERMIT NO. 28-733-08 Charleston Park
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	4	2
Clay		4	11	7
Calichie		11	13	2
Clay		13	24	11
Calichie		24	27	3
Clay		27	36	9
Calichie		36	38	2
Clay		38	53	15
Calichie	WB	53	56	3
Clay		56	65	9
Calichie	WB	65	67	2
Clay		67	74	7
Calichie	WB	74	78	4
Clay		78	88	10
Calichie	WB	88	93	5
Clay		93	106	13
Calichie	WB	106	109	3
Clay		109	114	5
Calichie	WB	114	117	3
Clay		117	122	5
Calichie	WB	122	126	4
Clay		126	137	11
Calichie	WB	137	140	3

DONR/DWR MAR 26 1996 LAS VEGAS OFFICE

Date started February 22, 1996
Date completed February 24, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Out
Size perforation 8" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling
Contractor
Address P.O. Box 4220
Contractor
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 3-18-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627