WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50915 In book
Permit No.
Basin 162

NOTICE OF INTENT NO. 15046

1. OWNER Owen Palmer
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3351 Hardy

2. LOCATION SW ¼ SE ¼ Sec. 13 T. 20 S N/S R. 52 E NVE County
PERMIT NO. (Issued by Water Resources) 28-661-09 (Parcel No.) Charleston Park (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	3	3'
CALICHE		3	6	3'
CLAY		6	17	11'
CALICHE		17	19	2'
CLAY		19	33	14
CALICHE		33	37	4'
CLAY		37	44	7'
CALICHE		44	46	2'
CLAY		46	53	7'
CALICHE	W.B	53	55	2'
CLAY		55	67	12'
CALICHE	W.B	67	74	7'
CLAY		74	89	15'
CALICHE	W.B	89	93	4'
		93	104	11'
CALICHE	W.B	104	106	2'
		106	117	11'
CALICHE	W.B	117	123	6'
		123	136	13'
CALICHE	W.B	136	138	2'
CLAY		138	140	2'

RECEIVED MAR 26 1996 LAS VEGAS OFFICE

Date started 2-26, 1996
Date completed 2-28, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12 1/4	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Sawcut
Size perforation 1/8" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address PO box 4220 (Contractor)
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dean
By driller performing actual drilling on site or contractor
Date 3-18-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627